

Test Report No. 1446/2

Date Issued: 15 October, 2007

Product: Integra Switchboards
2 x 100 x 10 mm busbar system ($I_n = 2500$ A)

Clients rating: 415 V, 50 Hz
 $I_{cw} = 63$ kA, 1.0 s

Client: Integra Switchboards
7/21 Duntroon Street
Brendale 4500
Australia

Nature of tests: Verification of short-circuit withstand strength of the main busbars according to Clause 8.2.3.2.3 b) of AS/NZS 3439.1:2002

Result: The products withstood the tests, refer results herein.

Prepared by:



John Strugarek

NATA Approved Signatory:



Antony K. Milovac

Tested at: ITACS High Power

ITACS Head Office & EMC
4-6 Second Street,
Bowden, South Australia 5007
Postal PO Box 300
Hindmarsh, South Australia 5007
Telephone (08) 8346 8680
Facsimile (08) 8346 7072
Email: itacs@itacslab.com

ITACS High Power
27 Sheehan Road,
Postal PO Box 5140
Heidelberg West DC
Victoria 3081
Telephone (03) 9458 3988
Facsimile (03) 9458 3172

ITACS HAE
PO Box 7212
Wilberforce NSW 2756
Telephone/Facsimile:
(02) 4576 3189

ITACS (HK) Ltd.
Approval Safety Testing
Room 707, West 7/F, Building 201
Tai ran Road 4, Che gong miao
Industrial Estate,
Fulton District, Shenzhen
P. R. C.
Telephone/Facsimile:
(0755) 8238 3913



ACCREDITATION No. 1700

ITACS[®]

International Testing and
Certification Services Pty. Ltd.
ABN 60 098 886 563
www.itacslab.com

This document is issued in accordance with
NATA's accreditation requirements.

Accredited for compliance
with ISO/IEC 17025
Technical Competence
NATA is a signatory to the ILAC
Mutual Recognition Arrangement
for the mutual recognition of the
equivalence of testing and
calibration reports.
World Wide Recognition